

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1005-01	Hall by Room 7	BF	App	<1.0	6/4/2021	-	-	-	None	-	-	-
1005-02	Hall by Room 7	WF	App		8/24/2022	-	-	-	None	Non-functional on 8/24/2022	-	-
1007-01	Hall by Auditorium	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-
1012-01	Hall by Room 26	BF	App	<1.0	6/4/2021	-	-	-	None	-	-	-
1012-02	Hall by Room 26	WF	App		8/24/2022	-	-	-	None	Non-functional on 8/24/2022	-	-
1016-02	Room 28	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-
1017-02	Room 30	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-
1018-02	Room 32	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-
1019-02	Room 34	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-
1020-02	Room 36	WF	App		6/4/2021	-	-	-	None	-	-	-
1021-02	Room 38	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-
1022-02	Room 39	WF	App	1.33	6/4/2021	-	-	-	None	-	-	-
1026-02	Room 31	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-
1027-02	Room 29	WF	App	5.21	6/4/2021	-	-	-	None	-	-	-
1028-02	Storage Room 25	WF	App	29.1	6/4/2021				Additional Sampling Required			
1029-03	Room 12	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-
1030-02	Room 14	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-
1031-02	Room 16	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-
1032-02	Room 18	WF	App	16	6/4/2021				Additional Sampling Required			
1038-02	Room 17	WF	App	2.47	6/4/2021	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1039-02	Room 15	WF	App		6/4/2021	-	-	-	None	Removed From Service	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1009-1	Room 3	WF	App		6/4/2021	-	-	-	None	Removed from service	-	-
1012-1	Hall by Room 4	WF	App		6/4/2021	-	-	-	None	Removed from service	-	-
1012-2	Hall by Room 4	BF	App	<1.0	6/4/2021	-	-	-	None		-	-
1013-1	Room 4	WF	App		6/4/2021	-	-	-	None	Removed from service	-	-
1015-1	Room 9	WF	App	5.04	8/24/2022	-	-	-	None		-	-
1018-1	Hall by Room 13	WF	App	2.36	8/24/2022	-	-	-	None		-	-
1020-1	Room 13	WF	App		6/4/2021	-	-	-	None	Removed from service	-	-
1023-1	Room 15	WF	App		6/4/2021	-	-	-	None	Removed from service	-	-
1025-1	Room 6	WF	App		6/4/2021	-	-	-	None	Removed from service	-	-
1026-1	Room 11	WF	App		6/4/2021	-	-	-	None	Removed from service	-	-
1027-1	Hall by Room 6	WF	App	26.3	8/24/2022				Additional Sampling Required			
1028-1	Room 8	WF	App		6/4/2021	-	-	-	None	Removed from service	-	-

Laboratory Report

NYE Report #: 2224377-22813

August 28, 2022

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Dryden Street Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on August 24, 2022. New York Environmental analyzed the samples on August 25, 2022 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	24 Aug 2022
Date Received:	24 Aug 2022
Date Analyzed:	25 Aug 2022

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
220824O051	1	Hall by Room 13-WF, Initial	1.00	2.36	µg/L	
220824O052	2	Hall by Room 6-WF, Initial	1.00	26.3	µg/L	H
220824O053	3	Room 9-WF, Initial	1.00	5.04	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1003-2	Room 35	WF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1004-2	Room 33	WF	App	2.06	8/24/2022	-	-	-	None	-	-	-
1005-2	Room 32	WF	App	1.42	8/24/2022	-	-	-	None	-	-	-
1006-2	Room 31	WF	App	1.71	8/24/2022	-	-	-	None	-	-	-
1007-2	Room 30	WF	App	1.26	8/24/2022	-	-	-	None	-	-	-
1008-2	Room 29	WF	App	1.28	8/24/2022	-	-	-	None	-	-	-
1009-2	Room 28	WF	App	2	8/24/2022	-	-	-	None	-	-	-
1010-2	Room 27	WF	App	1.94	8/24/2022	-	-	-	None	-	-	-
1011-2	Room 26	WF	App	1.97	8/24/2022	-	-	-	None	-	-	-
1012-2	Room 25	WF	App	2.76	8/24/2022	-	-	-	None	-	-	-
1013-2	Room 24	WF	App	4.05	8/24/2022	-	-	-	None	-	-	-
1014-2	Room 23	WF	App	1.58	8/24/2022	-	-	-	None	-	-	-
1018-2	Room 20	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1019-2	Room 21	WF	App	1.06	8/24/2022	-	-	-	None	-	-	-
1020-2	Room 22	WF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1021-2	Room 19	WF	App	9.39	8/24/2022	-	-	-	None	-	-	-
1022-2	Room 18	WF	App	1.89	8/24/2022	-	-	-	None	-	-	-
1023-2	Room 17	WF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1024-2	Room 16	WF	App	1.49	8/24/2022	-	-	-	None	-	-	-
1025-2	Room 15	WF	App	2.05	8/24/2022	-	-	-	None	-	-	-
1026-2	Room 14	WF	App	5.41	8/24/2022	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1027-2	Room 13	WF	App	2.87	8/24/2022	-	-	-	None	-	-	-
1028-2	Room 12	WF	App	1.39	8/24/2022	-	-	-	None	-	-	-
1029-2	Room 11	WF	App	2.54	8/24/2022	-	-	-	None	-	-	-
1031-2	Room 10	WF	App	2.08	8/24/2022	-	-	-	None	-	-	-
1037-2	Room 4	WF	App	3.43	8/24/2022	-	-	-	None	-	-	-
1038-2	Room 3	WF	App	2.89	8/24/2022	-	-	-	None	-	-	-
1039-2	Room 2	WF	App	2.16	8/24/2022	-	-	-	None	-	-	-
1040-2	Room 1	WF	App	1.5	8/24/2022	-	-	-	None	-	-	-
1041-2	Assistant Principal's Office	WF	App		8/24/2022	-	-	-	None	Removed From Service	-	-
1043-2	Main Office	WF	App		8/24/2022	-	-	-	None	Removed From Service	-	-
1050-1	Hallway by Gym	WF	App	<1.0	8/24/2022	-	-	-	None		-	-
1050-2	Hallway by Gym	BF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1051-1	Gym	WF	App	<1.0	8/24/2022	-	-	-	None		-	-
1051-2	Gym	BF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1052-2	Room 34	WF	App	2	8/24/2022	-	-	-	None	-	-	-
1053-1	Portable L	WF	App	5.32	8/24/2022	-	-	-	None		-	-
1054-1	Portable R	WF	App	41.2	8/24/2022				Additional Sampling Required			

Laboratory Report

NYE Report #: 2224374-22810

August 28, 2022

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Park Avenue School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on August 24, 2022. New York Environmental analyzed the samples on August 25, 2022 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	24 Aug 2022
Date Received:	24 Aug 2022
Date Analyzed:	25 Aug 2022

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
220824O005	1	Room 35-WF, Initial	1.00	<1.00	µg/L	
220824O006	2	Room 33-WF, Initial	1.00	2.06	µg/L	
220824O007	3	Room 32-WF, Initial	1.00	1.42	µg/L	
220824O008	4	Room 31-WF, Initial	1.00	1.71	µg/L	
220824O009	5	Room 30-WF, Initial	1.00	1.26	µg/L	
220824O010	6	Room 29-WF, Initial	1.00	1.28	µg/L	
220824O011	7	Room 28-WF, Initial	1.00	2.00	µg/L	
220824O012	8	Room 27-WF, Initial	1.00	1.94	µg/L	
220824O013	9	Room 26-WF, Initial	1.00	1.97	µg/L	
220824O014	10	Room 25-WF, Initial	1.00	2.76	µg/L	
220824O015	11	Room 24-WF, Initial	1.00	4.05	µg/L	
220824O016	12	Room 23-WF, Initial	1.00	1.58	µg/L	
220824O017	13	Room 21-WF, Initial	1.00	1.06	µg/L	
220824O018	14	Room 22-WF, Initial	1.00	<1.00	µg/L	
220824O019	15	Room 19-WF, Initial	1.00	9.39	µg/L	
220824O020	16	Room 18-WF, Initial	1.00	1.89	µg/L	
220824O021	17	Room 17-WF, Initial	1.00	<1.00	µg/L	
220824O022	18	Room 16-WF, Initial	1.00	1.49	µg/L	
220824O023	19	Room 15-WF, Initial	1.00	2.05	µg/L	
220824O024	20	Room 14-WF, Initial	1.00	5.41	µg/L	
220824O025	21	Room 13-WF, Initial	1.00	2.87	µg/L	
220824O026	22	Room 12-WF, Initial	1.00	1.39	µg/L	
220824O027	23	Room 11-WF, Initial	1.00	2.54	µg/L	
220824O028	24	Room 10-WF, Initial	1.00	2.08	µg/L	
220824O029	25	Room 4-WF, Initial	1.00	3.43	µg/L	
220824O030	26	Room 3-WF, Initial	1.00	2.89	µg/L	



Date Collected:	24 Aug 2022
Date Received:	24 Aug 2022
Date Analyzed:	25 Aug 2022

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
220824O031	27	Room 2-WF, Initial	1.00	2.16	µg/L	
220824O032	28	Room 1-WF, Initial	1.00	1.50	µg/L	
220824O033	29	Hallway by Gym-WF, Initial	1.00	<1.00	µg/L	
220824O034	30	Gym, Initial	1.00	<1.00	µg/L	
220824O035	31	Room 34-WF, Initial	1.00	2.00	µg/L	
220824O036	32	Portable L-WF, Initial	1.00	5.32	µg/L	
220824O037	33	Portable R-WF, Initial	1.00	41.2	µg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1009-1	Room 17	WF	App	<1.0	8/24/2022	-	-	-	None		-	-
1010-1	Room 19	WF	App	7.66	8/24/2022	-	-	-	None	-	-	-
1016-1	Room 18	WF	App	26	8/24/2022				Additional Sampling Required			
1017-1	Room 16	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1018-1	Room 14	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1020-1	Hall by Gym	WF	App	<1.0	8/24/2022	-	-	-	None		-	-
1020-2	Hall by Gym (Bottle Filler)	BF	App	<1.0	6/3/2021	-	-	-	None	-	-	-
1028-1	Room 10	WF	App	1.27	6/3/2021	-	-	-	None	-	-	-
1029-1	Room 8	WF	App	64.8	8/24/2022				Additional Sampling Required			
1030-1	Room 6	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1031-1	Room 4	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1032-1	Room 2	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1033-1	Room "F"	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1034-1	Room "G"	WF	App	11.6	8/24/2022	-	-	-	None		-	-
1035-1	Room 1	WF	App	4.91	8/24/2022	-	-	-	None		-	-
1036-1	Room 3	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1037-1	Room 5	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-

Laboratory Report

NYE Report #: 2224375-22811

August 28, 2022

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Powells Lane School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on August 24, 2022. New York Environmental analyzed the samples on August 25, 2022 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	24 Aug 2022
Date Received:	24 Aug 2022
Date Analyzed:	25 Aug 2022

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
220824O038	1	Hall byRoom 17-BK, Initial	1.00	<1.00	µg/L	
220824O039	2	Room 19-WF, Initial	1.00	7.66	µg/L	
220824O040	3	Room 18-WF, Initial	1.00	26.0	µg/L	H
220824O041	4	Hall by Gym-WF, Initial	1.00	<1.00	µg/L	
220824O042	5	Room 8-WF, Initial	1.00	64.8	µg/L	E,H
220824O043	6	Room G-WF, Initial	1.00	11.6	µg/L	
220824O044	7	Room 1-WF, Initial	1.00	4.91	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
0003-2	Room B21	WF	App	1.7	8/24/2022	-	-	-	None	-	-	-
0004-2	Room B20-Wood Shop	WF	App	6.5	8/24/2022	-	-	-	None	-	-	-
1002-1	Cafeteria	WF	App	1.7	8/24/2022	-	-	-	None	Removed from Service	-	-
1003-1	Team Room	WF	App		8/24/2022	-	-	-	None	Removed from Service	-	-
1009-1	Hallway by Room 109 & 114	WF	App	6.13	8/24/2022	-	-	-	None		-	-
1014-1	Hallway by Nurse's Office	WF	App	<1.0	8/24/2022	-	-	-	None		-	-
1024-1	Auditorium by Girl's Bathroom	WF	App		8/24/2022	-	-	-	None	Permanently Removed from Service	-	-
1026-1	Auditorium by Boy's Bathroom	WF	App		8/24/2022	-	-	-	None	Permanently Removed from Service	-	-
1029-1	Hallway by Library	WF	App	<1.0	8/24/2022	-	-	-	None		-	-
1033-1	Hallway by Room 4	WF	App		8/24/2022	-	-	-	None	Removed from Service	-	-
1036-1	Auditorium Lobby-Left	WF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1036-2	Auditorium Lobby-Right	WF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1036-3	Auditorium Lobby-Right	BF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1037-1	New Wing, 1st Floor Hall-Left	WF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1037-2	New Wing, 1st Floor Hall-Right	WF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1037-3	New Wing, 1st Floor Hall-Right	BF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1038-1	New Wing by Room 220-Left	WF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1038-2	New Wing by Room 220-Right	WF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1038-3	New Wing by Room 220-Right	BF	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1093-1	New Wing Nurse's Office	SK	App	<1.0	8/24/2022	-	-	-	None	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1040-1	New Wing Main Office Kitchenette	SK	App	<1.0	8/24/2022	-	-	-	None	-	-	-
1041-1	New Wing Wellness Room	SK	App	2.86	8/24/2022	-	-	-	None	-	-	-
2002-1	Hallway by Room 207	WF	App		8/24/2022	-	-	-	None	Removed from Service	-	-
2008-1	Hallway by Room 200	WF	App	<1.0	8/24/2022	-	-	-	None		-	-
3002-1	Hallway by Room 303	WF	App	9.97	8/24/2022	-	-	-	None	-	-	-

Laboratory Report

NYE Report #: 2224378-22814

August 28, 2022

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Westbury Middle School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on August 24, 2022. New York Environmental analyzed the samples on August 25, 2022 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	24 Aug 2022
Date Received:	24 Aug 2022
Date Analyzed:	25 Aug 2022

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
220824O054	1	Room B20, Wood Shop-WF, Initial	1.00	6.50	µg/L	
220824O055	2	Hallway by Nurse's Office-WF, Initial	1.00	<1.00	µg/L	
220824O056	3	Hallway by Room 109-WF, Initial	1.00	6.13	µg/L	
220824O057	4	Auditorium Lobby, Left-WF, Initial	1.00	<1.00	µg/L	
220824O058	5	Auditorium Lobby, Right-WF, Initial	1.00	<1.00	µg/L	
220824O059	6	Auditorium Lobby, Right-BF, Initial	1.00	<1.00	µg/L	
220824O060	7	New Wing, 1st Floor, Left-WF, Initial	1.00	<1.00	µg/L	
220824O061	8	New Wing, 1st Floor, Right-WF, Initial	1.00	<1.00	µg/L	
220824O062	9	New Wing, 1st Floor, Right-BF, Initial	1.00	<1.00	µg/L	
220824O063	10	New Wing, 2nd Floor, by Room 220, Left-WF, Initial	1.00	<1.00	µg/L	
220824O064	11	New Wing, 2nd Floor, by Room 220, Right-WF, Initial	1.00	<1.00	µg/L	
220824O065	12	New Wing, 2nd Floor, by Room 220, Right-BF, Initial	1.00	<1.00	µg/L	
220824O066	13	New Wing, Nurse's Office-SK, Initial	1.00	<1.00	µg/L	
220824O067	14	New Wing, Main Office Kitchenette-SK, Initial	1.00	<1.00	µg/L	
220824O068	15	New Wing, Wellness Room-SK, Initial	1.00	2.86	µg/L	
220824O069	16	Hallway by Room 200-WF, Initial	1.00	<1.00	µg/L	
220824O070	17	Hallway by Library-WF, Initial	1.00	<1.00	µg/L	
220824O071	18	Hallway by Room 303-WF, Initial	1.00	9.97	µg/L	
220824O072	19	Kitchen Steamer-SK, Initial	1.00	4.62	µg/L	
220824O073	20	kitchen Potfiller-PF, Initial	1.00	22.5	µg/L	H
220824O074	21	Kitchen Ice Machine-IM, Initial	1.00	<1.00	µg/L	
220824O075	22	Kitchen Island, 2-Bay-SK, Initial	1.00	<1.00	µg/L	
220824O076	23	Kitchen Island-SK, Initial	1.00	<1.00	µg/L	
220824O077	24	Serving Line by Kitchen Prep-SK, Initial	1.00	<1.00	µg/L	
220824O078	25	Serving Line Prep-SK, Initial	1.00	<1.00	µg/L	
220824O079	26	Room B21-WF, Initial	1.00	1.70	µg/L	

Date Collected:	24 Aug 2022
Date Received:	24 Aug 2022
Date Analyzed:	25 Aug 2022

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
--------	-----	-----------------------------	-----	--------	-------	------

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1002-01	Main Cafeteria	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1003-01	Hall by Main Entrance	BF	App	<1.0	6/3/2021	-	-	-	None	-	-	-
1003-02	Hall by Main Entrance	WF	App	<1.0	8/24/2022	-	-	-	None		-	-
1009-02	Faculty Room	WF	App	<1.0	6/3/2021	-	-	-	None	-	-	-
1009-03	Faculty Room	BF	App	<1.0	6/3/2021	-	-	-	None	-	-	-
1011-01	Hall by Room 111	WF	App	10	8/24/2022	-	-	-	None		-	-
1016-01	Hall by Room 119	WF	App	2.2	8/24/2022	-	-	-	None		-	-
1026-01	Hall by Room 129	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1035-01	Hall by Room 153	WF	App	26.1	8/24/2022				Additional Sampling Required			
1039-01	Hall by Room 159	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1045-01	Boy's Locker Room Pool Bathroom	WF	App	11.5	6/3/2021	-	-	-	None	-	-	-
1045-07	Boy's Locker Room	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1045-08	Boy's Locker Room Ice Machine	IM	App	<1.0	8/24/2022							
1049-01	Hall by Room 178 Left	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1049-02	Hall by Room 178 Right	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1049-03	Hall by Room 178 Right	BF	App	<1.0	6/3/2021	-	-	-	None	-	-	-
1050-01	Hall by Room 177 Left	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1050-02	Hall by Room 177 Right	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1050-03	Hall by Room 177 Right	BF	App	<1.0	6/3/2021	-	-	-	None	-	-	-
1057-01	Hall by New Cafeteria Left	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1057-02	Hall by New Cafeteria Right	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
1057-03	Hall by New Cafeteria Right	BF	App	<1.0	6/3/2021	-	-	-	None	-	-	-
1062-01	Gym	WF	App	<1.0	6/2/2021	-	-	-	None		-	-
2002-01	Hall by Room 256	WF	App		8/24/2022	-	-	-	None	Removed from service	-	-
2002-02	Hall by Room 256	BF	App	<1.0	8/24/2022	-	-	-	None		-	-

Laboratory Report

NYE Report #: 2224376-22812

August 28, 2022

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Westbury High School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on August 24, 2022. New York Environmental analyzed the samples on August 25, 2022 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	24 Aug 2022
Date Received:	24 Aug 2022
Date Analyzed:	25 Aug 2022

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
220824O045	1	Hall by Main Entrance-WF, Initial	1.00	<1.00	µg/L	
220824O046	2	Hall by Room 111-WF, Initial	1.00	10.0	µg/L	
220824O047	3	Hall by Room 119-WF, Initial	1.00	2.20	µg/L	
220824O048	4	Hall by Room 153-WF, Initial	1.00	26.1	µg/L	H
220824O049	5	Boys Locker Room Ice Machine-IM, Initial	1.00	<1.00	µg/L	
220824O050	6	Hall by Room 256-BF, Initial	1.00	<1.00	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.